

# ANEMOSTAT<sup>®</sup>


## AIR TERMINAL CONTROLS

Control Package  
**DD - P - 3000**

- DUAL DUCT
- PNEUMATIC CONTROLS
- VAV HEATING & COOLING
- PRESSURE INDEPENDENT

- DIRECT ACTING THERMOSTAT
- NORMALLY OPEN COLD DAMPER
- NORMALLY CLOSED HOT DAMPER

### I - T3 SEQUENCE



————— **FACTORY PIPING**  
- - - - - **FIELD PIPING**

REFER TO ANEMOSTAT "CONTROLS MANUAL" (CM-1) FOR ADJUSTMENT & TROUBLESHOOTING PROCEDURES.

**JOB NAME:**  
**SUBMITTED BY:**  
**DATE:**

**DWG #:** DD-P-3000.1  
**REV:** A  
**DATE:** 4-13-07