


Control Package
SD - P - 3100

- SINGLE DUCT
- PNEUMATIC CONTROLS
- VAV COOLING
- OPTIONAL HOT WATER HEAT
- PRESSURE INDEPENDENT
- DIRECT ACTING THERMOSTAT
- NORMALLY OPEN DAMPER



-- FACTORY PIPING
-- FIELD PIPING

REFER TO ANEMOSTAT "CONTROLS MANUAL" (CM-1) FOR ADJUSTMENT & TROUBLESHOOTING PROCEDURES.

JOB NAME: SUBMITTED BY:

DATE:

DWG #: SD-P-3100.1

REV: -

DATE: 8-7-06