


Control Package
SD - P - 3275

- SINGLE DUCT
- VAV COOLING
- PRESSURE INDEPENDENT
- PNEUMATIC CONTROLS
- DIRECT ACTING THERMOSTAT
- NORMALLY CLOSE DAMPER
- DUAL MINIMUM (REHEAT)
- OPTIONAL HOT WATER REHEAT



FACTORY PIPING
FIELD PIPING

REFER TO ANEMOSTAT "CONTROLS MANUAL" (CM-1) FOR ADJUSTMENT & TROUBLESHOOTING PROCEDURES.

JOB NAME: SUBMITTED BY:

DATE:

DWG #: SD-P-3275.1

REV: -

DATE: 12-7-12