


Control Package

SD - P - 3375

- SINGLE DUCT
- VAV COOLING
- PRESSURE INDEPENDENT
- PNEUMATIC CONTROLS
- REVERSE ACTING THERMOSTAT
- NORMALLY OPEN DAMPER
- DUAL MINIMUM (REHEAT)
- OPTIONAL HOT WATER REHEAT



FACTORY PIPINGFIELD PIPING

REFER TO ANEMOSTAT "CONTROLS MANUAL" (CM-1) FOR ADJUSTMENT & TROUBLESHOOTING PROCEDURES.

JOB NAME: SUBMITTED BY:

DATE:

DWG #: SD-P-3375.1

REV -

DATE: 12-5-12